


DIP SWITCH SETTING



1 2

TORQUE AND LIMIT SWITCH OPERATION			
SWITCH	CLOSE	INTERMEDIATE	OPEN
CLS 1-2			
CLS 1-3			
OLS 1-2			
OLS 1-3			
ACLS1-2			
ACLS1-3			
AOLS1-2			
AOLS1-3			

SYMBOL	DESCRIPTION	RATING
CLS	CLOSE LIMIT SWITCH	250VAC 10A
OLS	OPEN LIMIT SWITCH	250VAC 10A
ACLS	AUX. CLOSE LIMIT SWITCH	250VAC 16A
AOLS	AUX. OPEN LIMIT SWITCH	250VAC 16A
TP	THERMAL PROTECTOR	250VAC 15A

*EACH ACTUATOR SHOULD BE POWERED THROUGH IT'S OWN INDIVIDUAL SWITCH OR RELAY CONTACTS TO PREVENT CROSS FEED BETWEEN TWO OR MORE ACTUATORS.

PART NAME		AC WIRING DIAGRAM	
STANDARD			
DWG. NO		HQ-7420-A	
DATE	2006.06.02	ISSUE REF:	A
ACTUATED SOLUTIONS LTD TEL: (01243) 827469 FAX: (01243) 829418			
APPLICATION			
DOC : WD-01 1-09-2008			